
DANGER PLATE
PL 225 X 2 – Lg. 455

RED ON WHITE BACKGROUND : TOP SKULL AND CROSS BONES
MIDDLE DANGER MARK
330000 VOLTS MARK



PROGRESSIVE TOWER
NUMBER IN THE SECTION


NUMBER PLATE
PL 170 X 2 – Lg. 455
(BLACK NUMBERS WHITE BACKGROUND)


PROGRESSIVE TOWER NUMBERING IN EACH
KILOMETRE AND PROGRESSIVE KILOMETRAGE

AERIAL NUMBER PLATE
PL 225 X 2 –Lg. 455
(COLOURS : RED NUMBERS ON YELLOW BACKGROUND)

PHASE IDENT. NO. 3
PL ø76 X 2
(COLOURS : RED, YELLOW, BLUE)

TOWER SIGNS – MOUNTING LOCATION





CIRCUIT
IDENTIFICATION
PL 76 X 2 –Lg. 200
(BLACK LETTERS ON WHITE BACKGROUND)

NOTES

1 – ALL THE PLATES (DANGER , NUMBER, AERIAL, PHASE AND CIRCUIT PLATE) ARE MADE IN STEEL COVERED BY VITREOUS ENAMELLED FINISH –
2 – ALL HOLES ARE ø14mm. FOR BOLTS ø12mm. –
3 – ALL DIMENSION ARE IN mm. –
4 –CIRCUIT IDENTIFICATION PLATE SEE DWG. NO. HD136 sh. 3. –

PLATES LIST REQUIRED FOR EACH TOWER		LIST FOR AERIAL NUMBER PL. REQUIRED FOR FIRST TOWER IN EACH KILOMETRE	
PCS.	DESCRIPTION	PCS.	DESCRIPTION
2	DANGER PLATES	1	AERIAL PLATE
2	NUMBER PLATES	4	BOLTS ø12 X 40 WITH ONE SPRING LOCK WASHER
3	PHASE PLATES { RED, YELLOW, BLUE }	4	STEEL WASHERS Th. 3mm
1	CIRCUIT PLATE (SEE DWG. HD-136 Sh. 3)	8	FIBRE WASHERS
16	STEEL WASHERS Th. 3 mm		
16	BOLTS ø12 X 40 WITH SPRING LOCK WASHERS		
36	FIBRE WASHERS		

FOR TENDERING ONLY

DATE	REFERENCE DRAWING	NUMBER

REVISION

NO	BY	DATE	DESCRIPTION

APPROVED BY
DIRECTOR OF ENGINEERING PLANNING & DESIGN

THIS DRAWING IS THE PROPERTY OF GHANA
GRID COMPANY LTD. AND IS NOT TO BE COPIED
OR USED WITHOUT ITS WRITTEN PERMISSION

DATE	OCTOBER, 2020
SCALE	NONE
DRAWN BY	
DESIGNED BY	
CHECKED BY	

PROJECT
330KV TRANSMISSION LINE PROJECT

TITLE : TOWER SIGNS (TYPICAL DETAILS)

Ghana Grid Company Ltd
P.O Box CS 7979, Tema,Ghana
Tel:0303 304818 /0303 310310
Fax :0303 676180 /0303 303327
Email: gridco@gridcogh.com,web:www.gridco.com

GRIDCo
Backbone to Power Delivery

FOR APPROVAL	
FOR CONSTRUCTION	
FOR INFORMATION	

sheet size	Drawing no.	sheet	dev
A3	XXXX	1 / 1	XX